

| No. | WOID | Description | Craft | Location | Area Number | Custom Category | Request Date | Action Taken |
|-----|--------|---|---------------------|----------------------------------|--|-----------------|--------------|--|
| 1 | 313242 | Room 11A: please replace ceiling tiles that fell down due to rain water. Roof did not leak in the last heavy rain. | General Maintenance | Adams Elementary School | | Roofs/Rain | 12/16/2019 | Replaced tiles and checked after the rain |
| 2 | 312428 | Meeting Room 11A: appears to be new water damage on ceiling tiles next to ceiling hvac unit. Previously damaged tiles had been replaced. UPDATE Room 11A - very bad ceiling leak with this last rain. Ceiling tiles fell in and carpet saturated. This is the same area that leaks with each rain. Custodian had put down plastic and a trash can below but area of leak has expanded. Water filled trash can half way. | Roof | Adams Elementary School | | Roofs/Rain | 11/26/2019 | |
| 3 | 312431 | Room 10: ceiling tile damaged by rain is in danger of falling down. Reported previously. Concerned because of heavy rain forecast. Will have container placed below. | Roof | Adams Elementary School | | Roofs/Rain | 11/26/2019 | Remove damage ceiling tile Replaced with New |
| 4 | 312597 | Room 18 - rain water leaked in at the center of the ceiling | Roof | Adams Elementary School | | Roofs/Rain | 12/2/2019 | |
| 5 | 313499 | December 27, 2019: Water leak was found in Classrooms #3, #11, and #12. | Roof | Adams Elementary School | | Roofs/Rain | 12/30/2019 | |
| 6 | 312606 | Leak in the work room | Roof | Andersen Elementary School | Work room | Roofs/Rain | 12/2/2019 | |
| 7 | 312629 | Leak in room 20 | Roof | Andersen Elementary School | 20 | Roofs/Rain | 12/2/2019 | |
| 8 | 313451 | Leak in teachers work room. Carpet and counter was drenched | Roof | Andersen Elementary School | Teacher work room | Roofs/Rain | 12/26/2019 | |
| 9 | 316819 | Roof Leak found in room 1st grade room 16 | Roof | Andersen Elementary School | 16 | Roofs/Rain | 4/29/2020 | |
| 10 | 312455 | Hallway adjacent to staff lounge and staff restrooms--leak in ceiling | Roof | Back Bay/Monte Vista High School | | Roofs/Rain | 11/27/2019 | |
| 11 | 316120 | Leaks in roofing to ceiling tiles throughout school including nurses office and staff lounge | Roof | Back Bay/Monte Vista High School | Throughout school/nurses office and staff lounge | Roofs/Rain | 3/10/2020 | |
| 12 | 316236 | The roof is leaking at BESST Center, Room 116, SOY Music Room. They have moved the drums and other instruments so they stay dry. I sent pictures to Brigitte Besneatte in an email to show location of leak. It was above the drums. Thank you. | Roof | BESST Center | Room 116 | Roofs/Rain | 3/12/2020 | |
| 13 | 312744 | Ceiling in lab at HOPE Clinic (room 208) is actively leaking and there are puddles on the floor in the middle of the room. We have 2 basins to collect the drops in the middle of the floor which is a hazard. There are also leaks in other rooms in the clinic where the ceiling tiles are wet; rooms 204, 205, and 209. Thank you. | Roof | BESST Hope Clinic | 208, 209, 204, 205 | Roofs/Rain | 12/4/2019 | |
| 14 | 312223 | Please send someone to help with a leak in the ceiling in office C. | Roof | California Elementary School | | Roofs/Rain | 11/21/2019 | Please replace ceiling tile. Plumber had been out psychologist said it hadn't leaked sense last year there were no stains or leaks |
| 15 | 313438 | work room next to the kitchen has a roof leak when rain | Roof | California Elementary School | work room next to the kitchen | Roofs/Rain | 12/26/2019 | |
| 16 | 316223 | Please send someone to help with a leak in office A. | Roof | California Elementary School | Office A | Roofs/Rain | 3/12/2020 | |
| 17 | 312761 | leak from ceiling, please repair | Roof | College Park Elementary School | 14 | Roofs/Rain | 12/4/2019 | |
| 18 | 312170 | 30 sandbags needed for rain. Please expedite for rain today. | Grounds | College Park Elementary School | black top | Roofs/Rain | 11/20/2019 | |
| 19 | 312763 | 2 leaks, one by each entry. Please repair | Roof | College Park Elementary School | 1 | Roofs/Rain | 12/4/2019 | |
| 20 | 312508 | possible leak; ceiling tiles have water stains that were not there before the break. Please replace | Roof | College Park Elementary School | 13 | Roofs/Rain | 12/1/2019 | |
| 21 | 312446 | we have 2 leaks in the very back part of the stage; we have placed a black plastic bucket under the more profound leak. | Roof | College Park Elementary School | MPR backstage | Roofs/Rain | 11/27/2019 | |
| 22 | 312436 | there is a leak that continues in the same spot of the ceiling. Please repair | General Maintenance | College Park Elementary School | 23 | Roofs/Rain | 11/26/2019 | Original work order for leak(s) in rm 23 WO#312435 BB 12/2/19 |
| 23 | 312435 | light is out on a spot where leaking continues | Roof | College Park Elementary School | 23 | Roofs/Rain | 11/26/2019 | |
| 24 | 313500 | December 27, 2019: Small water leaks were found in rooms #12 & #21 | Roof | College Park Elementary School | | Roofs/Rain | 12/30/2019 | |
| 25 | 316237 | There is a leak in room 1 that the ceiling tile is caving in. The leak is on the ceiling of the student restroom and can become a hazard because it hard a tile floor, which may cause students to slip. There are more ceiling tiles that need to be replaced but this one seems to be the most priority. Please repair. Thank you. | Roof | College Park Elementary School | room 1 | Roofs/Rain | 3/12/2020 | |
| 26 | 316213 | there is a leak in the eaves in front of room 21. Pretty steady leak. Please repair. | Roof | College Park Elementary School | in front of roo 21 | Roofs/Rain | 3/12/2020 | |
| 27 | 316215 | there is a leak in the class that has a steady stream of drips coming down from red fire alarm device on ceiling, please repair. Thank you. | Roof | College Park Elementary School | room 14 | Roofs/Rain | 3/12/2020 | |

| | | | | | | | | |
|----|--------|--|---------------------|--------------------------------------|--|------------|------------|---|
| 28 | 316216 | there is a leak in the back of the class. please repair. Thank you. | Roof | College Park Elementary School | room 12 | Roofs/Rain | 3/12/2020 | |
| 29 | 316696 | water leaking into one of the light fixtures | Roof | College Park Elementary School | 14 | Roofs/Rain | 4/16/2020 | |
| 30 | 316603 | ceiling tiles are falling off due to do so much rain coming thru | Roof | College Park Elementary School | Room 1 | Roofs/Rain | 4/8/2020 | |
| 31 | 313449 | Planter outside nurse office continues to leak during rains, flooding office and cot room. Carpet may need to be removed. | Grounds | Corona del Mar High School | Nurse Office | Roofs/Rain | 12/26/2019 | Another more recent work order is requesting this planter to be removed. BB 1/14/20 |
| 32 | 312783 | There is a ceiling leak in Room 324 (AKA Science Office). There is a trashcan under the leak. Picture attached. Thank you | Roof | Corona del Mar High School | Room 324 | Roofs/Rain | 12/4/2019 | |
| 33 | 312787 | Please check the ceiling leak in Room 501 and replace the ceiling tiles. Picture attached. Thank you | Roof | Corona del Mar High School | Room 501 | Roofs/Rain | 12/4/2019 | |
| 34 | 312708 | Please assess and repair a water leak in the football weight room building. Thank you. | Roof | Corona del Mar High School | Football weightroom | Roofs/Rain | 12/3/2019 | |
| 35 | 312595 | Please assess and repair visible water damage in room 414 from the last storm. This is a Tech room and make computers are in the room with potential damage. Thank you. | Roof | Corona del Mar High School | 414 | Roofs/Rain | 12/2/2019 | |
| 36 | 312785 | ***URGENT*** Please fix the leak in the classroom wall (again) in Room 413. Same area as before. Not too bad of a leak but a puddle is starting to form on the carpet, again. Starting to get concerned about mold in the wall and under the carpet. Please fix ASAP. Thank you | Roof | Corona del Mar High School | Room 413 | Roofs/Rain | 12/4/2019 | |
| 37 | 312253 | ***URGENT*** There is water coming in from the ceiling in the team room on the pool deck. It seems pretty bad and I'm worried about damage and mold. The leak is in the back corner by the back door of the team room. Please send someone out to look at and fix ASAP. Thank you | Roof | Corona del Mar High School | Team Room on Pool Deck | Roofs/Rain | 11/21/2019 | |
| 38 | 313450 | Rain gutter over window planter is clogged and overflows into the planter that floods into the nurses' office. | Roof | Corona del Mar High School | Nurses' Office | Roofs/Rain | 12/26/2019 | |
| 39 | 313439 | Room 413; leak from under wall, left of windows, is soaking carpet. | General Maintenance | Corona del Mar High School | 413 | Roofs/Rain | 12/26/2019 | |
| 40 | 313440 | Room 428; leaking through light fixture at back of room. | Roof | Corona del Mar High School | 428 | Roofs/Rain | 12/26/2019 | |
| 41 | 313441 | Room 432; small leak at base of windows to the left. | Glazier | Corona del Mar High School | 432 | Roofs/Rain | 12/26/2019 | |
| 42 | 313442 | Room 433; small leak at base of window to the left. | Glazier | Corona del Mar High School | 433 | Roofs/Rain | 12/26/2019 | |
| 43 | 313264 | The window near the back corner of the classroom is leaking. Water has begun to pool on the carpet on the inside of the classroom. Please assess and repair. Thank you. | Glazier | Corona del Mar High School | 413 | Roofs/Rain | 12/17/2019 | |
| 44 | 313052 | There is a roof leak into that bathroom that has been there for a coup of years that needs to be checked and repaired. Thank you | Roof | Corona del Mar Middle School Enclave | Room 318 | Roofs/Rain | 12/11/2019 | |
| 45 | 313444 | Water leaking through the HVAC vents in boys locker room area closest to pool. | Roof | Costa Mesa High School | Boys locker room | Roofs/Rain | 12/26/2019 | Roof drain was snaked |
| 46 | 312686 | There are three light fixtures that are very short light poles that stick out the ground on the outside of the theater on the black box side that the glass was broken previously work order was submitted and the lights were covered with plastic sheeting and now the plastic sheeting has been ripped and rain is now able to get inside. Pic attached | Electrical | Costa Mesa High School | short light poles in ground outside of black box | Roofs/Rain | 12/3/2019 | |
| 47 | 313443 | Roof leaks in counseling area. | Roof | Costa Mesa High School | counseling area | Roofs/Rain | 12/26/2019 | Roof replacement added to project list for Summer 2020. |
| 48 | 312589 | There are down ceiling tiles and water damage (carpeting is wet) in the high school counseling office. | Water Leaks | Costa Mesa High School | Counseling office | Roofs/Rain | 12/2/2019 | Original work order 312292 BB 12/2/19 |
| 49 | 313872 | Leak from roof in middle of the classroom, one of the ceiling tiles has a small hole in the tile and water is dripping down from it. | Roof | Costa Mesa High School | 107 | Roofs/Rain | 1/9/2020 | |
| 50 | 313445 | In the music room the two small rooms inside water is leaking through the walls and flooding the carpet it is also flooding in the instrument storage room on the other side of the wall. | Roof | Costa Mesa High School | I-102 music room | Roofs/Rain | 12/26/2019 | |
| 51 | 313446 | Water leaking from the roof above the brick wall closest to the drinking fountains inside. | Roof | Costa Mesa High School | | Roofs/Rain | 12/26/2019 | |
| 52 | 313479 | water on the floor in electrical room in front of room 110 | Roof | Costa Mesa High School | In front of room 110 | Roofs/Rain | 12/27/2019 | |
| 53 | 312292 | Leak in CMHS counseling office | Roof | Costa Mesa High School | | Roofs/Rain | 11/22/2019 | |
| 54 | 316238 | Night custodial supervisor shut off faucet in girls restroom on Building "C". Water was running continuously. | Plumbing | CROP | restroom on building | Roofs/Rain | 3/12/2020 | |
| 55 | 312751 | There is a good leak in the classroom. It is in the back corner of the classroom. There is currently a red bucket under the leak and teachers are keeping an eye on it. | Roof | Davis Magnet School | 9 | Roofs/Rain | 12/4/2019 | |
| 56 | 312752 | There is a ceiling leak in the classroom. | Roof | Davis Magnet School | 8 | Roofs/Rain | 12/4/2019 | |

| | | | | | | | | |
|----|--------|--|---------------------|-----------------------------|------------------------|------------|------------|--|
| 57 | 312762 | When it rains there is a steady stream of water (see picture) at the door entry. It makes it very difficult for students to enter the classroom when it rains. | Roof | Davis Magnet School | 29 | Roofs/Rain | 12/4/2019 | |
| 58 | 312174 | Ceiling leak in room 3 computer lab | Roof | Davis Magnet School | Classroom 3 | Roofs/Rain | 11/20/2019 | |
| 59 | 313091 | Two roof leaks - one is near the front door and the other is on the far right corner under the cabinet counter area. Both currently have a bucket under them. This is a bungalow room. | Roof | Davis Magnet School | 31 | Roofs/Rain | 12/12/2019 | |
| 60 | 312918 | There is a leak near the west door. The leak is coming out of the conduit in the ceiling. There is a trashcan under the leak. | Roof | Davis Magnet School | 25 | Roofs/Rain | 12/6/2019 | |
| 61 | 313732 | classroom #25 has a leak | Roof | Davis Magnet School | 25 | Roofs/Rain | 1/6/2020 | |
| 62 | 313501 | Water leak was found in room "LLC" (Library Learning Center) | Roof | Davis Magnet School | | Roofs/Rain | 12/30/2019 | |
| 63 | 316180 | classroom # 36 inside by the little storage room, it's a leak from the roof. | Roof | Davis Magnet School | # 36 | Roofs/Rain | 3/11/2020 | |
| 64 | 316257 | There's a leak in the MPR, picture attach. | Roof | Davis Magnet School | roof leak | Roofs/Rain | 3/13/2020 | |
| 65 | 316219 | Leaking in classroom # 2, urgent please. | Roof | Davis Magnet School | # 2 | Roofs/Rain | 3/12/2020 | |
| 66 | 316271 | There's a leak in classroom # 26 | Roof | Davis Magnet School | # 26 | Roofs/Rain | 3/13/2020 | |
| 67 | 316343 | we have a leak in classroom number 4 by the clock | Roof | Early College High School | | Roofs/Rain | 3/23/2020 | |
| 68 | 313472 | we have raining ceiling leaks in classrooms numbers 8,11 and mpr storage room | Roof | Early College High School | | Roofs/Rain | 12/27/2019 | |
| 69 | 312617 | The ceiling tile at the front door are wet and looks like their has been a leak. | Roof | Eastbluff Elementary School | C6 | Roofs/Rain | 12/2/2019 | |
| 70 | 312445 | Please inspect window/ledge right inside of the entrance door to Superintendents office. Water leakage from above on window to the right of the entrance door. | General Maintenance | ED Center | Superintendents office | Roofs/Rain | 11/27/2019 | Repaired window weather seal above covered walk way in courtyard. Followed up after recent rain and found that no leaks were reported. |
| 71 | 312920 | Leak in scan room from rain- will also need new ceiling tile | Roof | ED Center | Human Resources | Roofs/Rain | 12/6/2019 | |
| 72 | 313503 | Not roof leaks. Water leaks were found in H.R, Leona's office, Kristen's Clark office, Board Room. 12/26/2019 - 12/27/2019 | General Maintenance | ED Center | | Roofs/Rain | 12/30/2019 | |
| 73 | 315778 | There is a leak in the ceiling in room 36. A water spot has shown up over the weekend from the rain. Please assess and repair. Thank you. | Roof | Ensign Intermediate School | Room 36 | Roofs/Rain | 3/2/2020 | |
| 74 | 312207 | There are major leaks in: Room 2 Room 41 Band Room | Roof | Ensign Intermediate School | Room 41 | Roofs/Rain | 11/21/2019 | fixed by air contractor |
| 75 | 312788 | There is a leak in room 21 and the band room. | Roof | Ensign Intermediate School | Room 21 and Band Room | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 76 | 312818 | Water leak in Boy's Locker Room and has flooded part of the space. Custodian has mopped it but with more rain coming this week, it will get worse. | Roof | Ensign Intermediate School | Boy's Locker Room | Roofs/Rain | 12/5/2019 | |
| 77 | 312748 | 1. Two big leaks in the main office teacher's lounge. We currently have two large trash cans underneath them. 2. Additional leak in room 6 above the ceiling fan. | Roof | Ensign Intermediate School | Main Office and Room 6 | Roofs/Rain | 12/4/2019 | fixed by contractor |
| 78 | 312750 | Leaks in room 22 and room 55. | Roof | Ensign Intermediate School | Room 55 and Room 22 | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 79 | 316260 | Leak in room 27 in the ceiling. Placed bucket underneath. Please patch and repair. | Roof | Ensign Intermediate School | Room 27 | Roofs/Rain | 3/13/2020 | |
| 80 | 316266 | Roof leak in room 21. Please assess and repair. | Roof | Ensign Intermediate School | Room 21 | Roofs/Rain | 3/13/2020 | |
| 81 | 313504 | Water leaks were found in rooms #1, #8, #9, #10, #24, #27, #29, #36, #38, band room, the-hive, main office (upstairs), cafeteria & gym. December 26-27, 2019 | Roof | Ensign Intermediate School | | Roofs/Rain | 12/30/2019 | |
| 82 | 312881 | Leak in the roof of room 10. Please repair. | Roof | Ensign Intermediate School | Room 10 | Roofs/Rain | 12/6/2019 | |
| 83 | 312451 | ADMIN BUILDING 2nd floor- has leak coming through light fixture in counselors office next to elevator. BUILDING J-Science Room has a leak. This should be the classroom across from the entrance to the gym CLASSROOM 27 has a leak away from FCU, not dripping on floor but ceiling tile is swelling. | Roof | Ensign Intermediate School | | Roofs/Rain | 11/27/2019 | |
| 84 | 313836 | Please repair the roof leak and replace the ceiling tile in room 703. | Roof | Estancia High School | room 703 | Roofs/Rain | 1/8/2020 | |
| 85 | 312961 | Please repair the roof leak in the ASB office. | Roof | Estancia High School | ASB office | Roofs/Rain | 12/9/2019 | |
| 86 | 312809 | Please repair the roof leak in the teachers dining room. | Roof | Estancia High School | | Roofs/Rain | 12/5/2019 | |
| 87 | 312810 | Please repair the roof leak in room 724. | Roof | Estancia High School | room 724 | Roofs/Rain | 12/5/2019 | |
| 88 | 312811 | Please repair the roof leak in room 703. | Roof | Estancia High School | room 703 | Roofs/Rain | 12/5/2019 | |

| | | | | | | | | |
|-----|--------|---|---------------------|---------------------------------|--------------------------|------------|------------|-------------------------------|
| 89 | 312812 | Please repair the roof leak in the library book room. | Roof | Estancia High School | Book room | Roofs/Rain | 12/5/2019 | |
| 90 | 312813 | Please repair the roof leak outside of the boys restroom by the front office. | Roof | Estancia High School | | Roofs/Rain | 12/5/2019 | |
| 91 | 312615 | We have seventeen rooms with minor to major leaks. Rooms 1,2,3,4,8,11,12,13,15,16,17,18,20,23,24,25, and 26. Rooms 26 and 17 have a hole where the tile got wet and fell down. Ask for Chris if you have any questions. | Roof | Harbor View Elementary School | | Roofs/Rain | 12/2/2019 | fixed by air contractor |
| 92 | 313487 | Rooms 24,20,19,17,12,14,16,D-1,4,3. All have roof leaks | Roof | Harbor View Elementary School | | Roofs/Rain | 12/29/2019 | |
| 93 | 316681 | There are small roof leaks from the rain in rooms 2, 3, 12, 15, 17,18, 19, 21, 22, 23, 24, 25, 26, and the office. Call Chris for questions. 714-287-6151. M-F, 9-1. | Roof | Harbor View Elementary School | | Roofs/Rain | 4/14/2020 | |
| 94 | 313505 | Small water leak was found in storage room next to building E-1 | Roof | Harper | | Roofs/Rain | 12/30/2019 | |
| 95 | 306832 | Room 27 - Numerous ceiling tiles are bowing down and have water marks and visible mold. See attached picture. | General Maintenance | Kaiser Elementary School | Room 27 | Roofs/Rain | 8/6/2019 | |
| 96 | 312235 | Roof leaking and ceiling tiles fell. | Roof | Killybrooke Elementary School | 5 | Roofs/Rain | 11/21/2019 | |
| 97 | 312685 | We have a few leaks, but one in particular looks like it's going to break and drop water on us. | Roof | Killybrooke Elementary School | 18 | Roofs/Rain | 12/3/2019 | |
| 98 | 312310 | Teacher reported wet spots on tile after rain. Possible roof leaks | Roof | Killybrooke Elementary School | 20 and 21 | Roofs/Rain | 11/22/2019 | |
| 99 | 313488 | Please repair new roof leaks [9, 18, Science Lab]. Thank you! | Roof | Killybrooke Elementary School | 9, 18, Science Lab | Roofs/Rain | 12/29/2019 | |
| 100 | 316150 | Please check for rain leak in corner of the science room. | Roof | Killybrooke Elementary School | | Roofs/Rain | 3/10/2020 | |
| 101 | 316225 | Psychologist's office has multiple leaks in roof. Water leaking through | Roof | Killybrooke Elementary School | Room E | Roofs/Rain | 3/12/2020 | |
| 102 | 312760 | Water leaking from the roof inside room 21 | Roof | Lincoln Elementary School | 22 | Roofs/Rain | 12/4/2019 | |
| 103 | 313506 | Small water leak was found in classroom #27. | Roof | Lincoln Elementary School | | Roofs/Rain | 12/30/2019 | |
| 104 | 313610 | Water leak from the roof in Art room | Roof | Lincoln Elementary School | 27 | Roofs/Rain | 1/2/2020 | |
| 105 | 313128 | Several ceiling tiles in the lounge in Building C came down sometime last night. There are others that seem to be buckling. | Roof | Lindbergh - Special Ed. | Building C | Roofs/Rain | 12/13/2019 | |
| 106 | 312825 | room 9 has a roof leak by windows on far side of room. SEE TEACHER | Roof | Mariners Elementary School | room 9 | Roofs/Rain | 12/5/2019 | |
| 107 | 312826 | Roof leak in room 10 by back door. Ceiling tile came down in room | Roof | Mariners Elementary School | ROOM 10 | Roofs/Rain | 12/5/2019 | |
| 108 | 312797 | Ceiling is leaking and tile fell down | Roof | Mariners Elementary School | 10 | Roofs/Rain | 12/4/2019 | |
| 109 | 313423 | Due to rain a water leak was found in classroom K-B | Roof | Mariners Elementary School | Classroom K-B | Roofs/Rain | 12/23/2019 | |
| 110 | 316897 | Room 25 has roof leak needs repair | Roof | Mariners Elementary School | room 25 | Roofs/Rain | 5/1/2020 | |
| 111 | 316572 | KB has a roof leak needs repair | Roof | Mariners Elementary School | KB | Roofs/Rain | 4/6/2020 | |
| 112 | 316616 | room 12 has a roof leak needs repair | Roof | Mariners Elementary School | room 12 | Roofs/Rain | 4/9/2020 | |
| 113 | 316618 | room 16 has roof leak needs repair | Roof | Mariners Elementary School | room 16 | Roofs/Rain | 4/9/2020 | |
| 114 | 316604 | room 10 has a roof leak needs repair | Roof | Mariners Elementary School | room 4 | Roofs/Rain | 4/8/2020 | |
| 115 | 312457 | Room KA, leak in ceiling | Roof | Mariners Elementary School | | Roofs/Rain | 11/27/2019 | |
| 116 | 312640 | Some ceiling tiles in room 20 show signs of water damage, probable leak in roof due to rain. Concern given forecast for more rain on Wednesday 12/04. Please see photo. | Roof | Newport Coast Elementary School | Room 20 | Roofs/Rain | 12/2/2019 | |
| 117 | 313508 | Small water leaks were found in rooms: #7, # 8, # 11, # 13, # 15, #20 & #21 from rains December 26-27, 2019 | Roof | Newport Coast Elementary School | | Roofs/Rain | 12/30/2019 | |
| 118 | 312745 | There is a new leak in the ceiling near the hallway door to room 21. The teacher placed a receptacle to catch the water. | Roof | Newport Elementary School | 21 | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 119 | 312452 | Not sure if it's Building A, but there is water coming down in the hallway between the teacher's lounge, music room, and custodial closet. | Roof | Newport Elementary School | | Roofs/Rain | 11/27/2019 | fixed by air contractor |
| 120 | 312604 | In hallway outside of teacher's lounge we have a leak from the roof. I believe it's from the construction project over the summer. Can we get someone here before the storm. | Water Leaks | Newport Elementary School | Next to teacher's lounge | Roofs/Rain | 12/2/2019 | Original wo#312452 BB 12/2/19 |
| 121 | 316596 | Roof is leaking in southwest corner next to window. | Roof | Newport Elementary School | Room # 16 | Roofs/Rain | 4/8/2020 | |
| 122 | 316597 | Teacher's lounge is leaking along south wall in four different areas. | Roof | Newport Elementary School | Room # 15 | Roofs/Rain | 4/8/2020 | |
| 123 | 316598 | Roof is leaking along north side wall and running down to counter top. | Roof | Newport Elementary School | Room # 14 | Roofs/Rain | 4/8/2020 | |
| 124 | 316599 | Roof is leaking by second door around or near return vent. | Roof | Newport Elementary School | Room # 19A | Roofs/Rain | 4/8/2020 | |

| | | | | | | | | |
|-----|--------|--|---------------------|-----------------------------------|---------------------------------------|------------|------------|--|
| 125 | 316674 | Roof leak in room 19. Any questions contact John Lewis, 714-412-6145 | Roof | Newport Elementary School | 19 | Roofs/Rain | 4/13/2020 | |
| 126 | 316179 | Roof drain is clogged | Plumbing | Newport Harbor High School | Social hall | Roofs/Rain | 3/11/2020 | |
| 127 | 312753 | Please repair roof leaks in varsity football locker room. Thank you. See Ryan. | Roof | Newport Harbor High School | Varsity Football Locker Room | Roofs/Rain | 12/4/2019 | |
| 128 | 312777 | This is TIME SENSITIVE - RELATED TO THE RAIN....There is a leak in the ceiling in the storage/stock room between Julie Karjala's classroom and Oscar Constandse's classroom. Please look at ASAP. Thank you - Annie Brown ext. 6314 | Roof | Newport Harbor High School | Stockroom between Room 203 & 204 | Roofs/Rain | 12/4/2019 | |
| 129 | 312766 | Please repair leak in roof in boys PE locker room. Thank you. see Ryan. | Roof | Newport Harbor High School | Boys PE Locker Room | Roofs/Rain | 12/4/2019 | |
| 130 | 312620 | THIS IS TIMELY....Jason Lynch's classroom has sustained significant roof leaks, post rain over the break. We are requesting this be looked at ASAP before the new storm hits this week. Thank you - Annie Brown ext. 6314. | Roof | Newport Harbor High School | Room 206 | Roofs/Rain | 12/2/2019 | |
| 131 | 312447 | Please repair and seal vents in football weight room as needed. Rain is leaking in. Thank you. See Ryan. | Roof | Newport Harbor High School | Football Weight Room | Roofs/Rain | 11/27/2019 | |
| 132 | 315109 | Please repair roof leak in social hall. Thank you. See Ryan. | Roof | Newport Harbor High School | Social Hall | Roofs/Rain | 2/10/2020 | |
| 133 | 316146 | The ceiling is leaking in the Social Hall. This happened the last time it rained. With the projected rainfall this week and into next - we are requesting district please look at ASAP. Thank you - Annie Brown ext 6314 | Roof | Newport Harbor High School | Social Hall | Roofs/Rain | 3/10/2020 | |
| 134 | 312786 | Please repair roof leak in stadium storage room 105 in vestibule. Thank you. See Ryan. | Roof | Newport Harbor High School | Stadium storage room 105 in vestibule | Roofs/Rain | 12/4/2019 | |
| 135 | 316227 | Please check roof leak in main gym. Thank you. See Ryan. | Roof | Newport Harbor High School | Main Gym | Roofs/Rain | 3/12/2020 | |
| 136 | 312756 | We're sprouting leaks throughout.... | Roof | Newport Heights Elementary School | Rm. 15 | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 137 | 312749 | There is a leak in two spots dripping onto students in the classroom. :0) They are made of sugar so you may want to hurry :0) | Roof | Newport Heights Elementary School | Rm. 19 | Roofs/Rain | 12/4/2019 | |
| 138 | 312741 | There are a few wet tiles that appear to be ready to bust in KB (see picture), and there is a leak at the front left in KA. | Roof | Newport Heights Elementary School | KA and KB | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 139 | 312742 | We need 10 covered pallets placed in front of the portables please. | General Maintenance | Newport Heights Elementary School | Rm. 26 - 30 | Roofs/Rain | 12/4/2019 | |
| 140 | 312454 | Active water leak...bucket placed underneath. Room K-A | Roof | Newport Heights Elementary School | | Roofs/Rain | 11/27/2019 | fixed by air contractor |
| 141 | 316578 | Roof leaks in room 4 and KA. | Roof | Newport Heights Elementary School | 4 & KA | Roofs/Rain | 4/6/2020 | |
| 142 | 312637 | A couple weeks ago someone came to fix a leak in my ceiling. It's still leaking...Ceiling Leakage. | Roof | Newport Heights Elementary School | RM 30 Science | Roofs/Rain | 12/2/2019 | |
| 143 | 316217 | There are several severe leaks in Rm. KA (Photos attached) | Roof | Newport Heights Elementary School | KA | Roofs/Rain | 3/12/2020 | |
| 144 | 316273 | Please see attached photos... Roof leak in Rm. 4 and tiles are falling from ceiling. Missed teacher by inches. | Roof | Newport Heights Elementary School | Rm 4 | Roofs/Rain | 3/13/2020 | |
| 145 | 316221 | There are several leaks in Rm. KB (photos attached) | Roof | Newport Heights Elementary School | KB | Roofs/Rain | 3/12/2020 | |
| 146 | 313509 | Small water leaks were found in rooms # K-B, # 4, # 7 & main office. [from rains during December 26-27, 2019] | Roof | Newport Heights Elementary School | | Roofs/Rain | 12/30/2019 | |
| 147 | 313510 | From rains during December 26-17, 2019: Small water leak found in room #21. | Roof | Paularino Elementary School | | Roofs/Rain | 12/30/2019 | |
| 148 | 316267 | Ceiling leak | Roof | Paularino Elementary School | 28 | Roofs/Rain | 3/13/2020 | |
| 149 | 316619 | roof leaking inside storage closet in classroom #20 | Roof | Paularino Elementary School | #20 | Roofs/Rain | 4/9/2020 | |
| 150 | 312729 | classroom # 10 has a roof leak | Roof | Pomona Elementary School | classroom#10 | Roofs/Rain | 12/3/2019 | |
| 151 | 312293 | Storage Bin used by after school program (Project Kidz Connect) has 2 leaks. Please check soon as there's a lot of equipment, books and paper that might get damaged if it rains again soon. Thank you. UPDATE 1/22/20: The water damage in the after school program bin has increased. Staff is reporting that there are more leaks in other places and there's more damage in their supplies. Please check asap. Thank you. | General Maintenance | Pomona Elementary School | After School Storage Bin | Roofs/Rain | 11/22/2019 | Grind rusted roofing and prepare for sealant to be applied. Patched numerous locations in storage bin. |
| 152 | 313480 | we have water leak from the roof On classrooms #2 #9 #10 #11 #21 and preschool #2 all six classrooms have water leak from the rain. we hope to get them repair thank you . | Roof | Pomona Elementary School | classroom #9 #10 #11 #21 #p2 k #2 | Roofs/Rain | 12/27/2019 | |
| 153 | 316220 | classroom #17 the roof is liquing | Roof | Pomona Elementary School | classroom #17 | Roofs/Rain | 3/12/2020 | |

| | | | | | | | | |
|-----|--------|--|------------------------|-------------------------------|-----------------------------|------------|------------|--|
| 154 | 316576 | we have a leak on the kitchen due to the heavy rain . thank you . | Roof | Pomona Elementary School | kitchen | Roofs/Rain | 4/6/2020 | |
| 155 | 316577 | we have a leak on the roof on room 11 , than you . | Roof | Pomona Elementary School | classroom # 11 | Roofs/Rain | 4/6/2020 | |
| 156 | 312206 | ROOF LEAKING ABOVE THE LIGHT THIS IS URGENT PLEASE FIX IT | Roof | Rea Elementary School | front office | Roofs/Rain | 11/21/2019 | |
| 157 | 313511 | From rains during December 26-27, 2019: Small water leak was found in room #11, no visible damage. | Roof | Rea Elementary School | | Roofs/Rain | 12/30/2019 | |
| 158 | 313496 | Please address rain water leaks through windows in the Tech Cafe in the following locations: Left window on wall facing Ed Center, window on wall facing parking lot/new houses, and right window on wall facing Ed Center. | Glazier | Sanborn | Tech Cafe | Roofs/Rain | 12/30/2019 | |
| 159 | 312769 | One pallette needed for flooded sidewalk near classrooms. Thank you! | General Maintenance | Sonora Elementary School | See custodian | Roofs/Rain | 12/4/2019 | Built and delivered on Monday 3-9 |
| 160 | 315966 | Ceiling leaking in custodian's office, above where he sits. (Not HVAC related as there is no HVAC in this location.) | Roof | Sonora Elementary School | Custodian's office | Roofs/Rain | 3/5/2020 | |
| 161 | 312383 | The last rain resulted in numerous leaks in the nurses' office. There were spots on the floor where water had come in from the ceiling and there was water coming through the light fixtures. | Roof | Victoria Elementary School | nurse | Roofs/Rain | 11/25/2019 | |
| 162 | 312220 | significant roof leaks in these classrooms | Roof | Victoria Elementary School | 5 6 | Roofs/Rain | 11/21/2019 | |
| 163 | 312221 | covered walkway between nurse's office and room 25 light fixture has 2-3" of standing water in it ... worried about when electricity comes on. See Bobbie for location if you can't find it. | Electrical | Victoria Elementary School | | Roofs/Rain | 11/21/2019 | Drained water from light fixture and sealed roof flashing for possible leak. |
| 164 | 312591 | Roof leaks | Roof | Victoria Elementary School | Rms.5,6, & 17 | Roofs/Rain | 12/2/2019 | |
| 165 | 313512 | From rain during December 26-27, 2019: Water leak was found in rooms #3 & #19 | Roof | Victoria Elementary School | | Roofs/Rain | 12/30/2019 | |
| 166 | 314211 | Roof leak in MPR - coming from a light fixture. See Bobbie | Roof | Victoria Elementary School | MPR | Roofs/Rain | 1/17/2020 | |
| 167 | 312444 | Per call by head custodian, Democ. Room 43 has a leak. He put a bucket under it and no computers or electronics are getting wet. Temoc is off duty so Jackie Tran is now searching other Whittier rooms for leaks. UPDATE: 12/4/19 roof leaking again and showing water damage in room 36. | Roof | Whittier Elementary School | | Roofs/Rain | 11/27/2019 | fixed by air contractor |
| 168 | 312614 | Leak in the ceiling near new AC system in both room 12 and front office. UPDATE: 12/4/19 leak showing through on wall with today's rain. | Roof | Whittier Elementary School | Room 12 and Main office | Roofs/Rain | 12/2/2019 | fixed by air contractor |
| 169 | 312211 | Roof leaks in classrooms 36, 42, and 43 caused ceiling tiles to fall. Leaks started after new AC installation. Please repair. | Roof | Whittier Elementary School | rooms 36, 42, and 43 | Roofs/Rain | 11/21/2019 | fixed by air contractor |
| 170 | 312743 | Leaks around new AC system in rooms 13 and 37. Room 13 has water leaking down to the floor and room 37 has visible water damage/leak on the wall. Please fix. Thank you. | Roof | Whittier Elementary School | Room 13 and Room 37 | Roofs/Rain | 12/4/2019 | fixed by air contractor |
| 171 | 316623 | Roof is leaking in room 43 | Roof | Whittier Elementary School | | Roofs/Rain | 4/9/2020 | |
| 172 | 316344 | Custodian reports leaks in rooms 35, 39 & 44 | Roof | Whittier Elementary School | 35, 44 & 39 | Roofs/Rain | 3/23/2020 | |
| 173 | 316218 | Leak next to vent for A/C | Roof | Whittier Elementary School | 12 | Roofs/Rain | 3/12/2020 | |
| 174 | 316207 | Heavy roof leak in room 40. Located between the AC duct and wall. Please repair. New AC system installed last summer. | Roof | Whittier Elementary School | Room 40 | Roofs/Rain | 3/12/2020 | |
| 175 | 313513 | From rains during December 26-27, 2019: Water leaks found in rooms: # 11, # 13, # 24, # 29, # 36, # 37, # 39, # 42, & # 43. | Roof | Whittier Elementary School | | Roofs/Rain | 12/30/2019 | |
| 176 | 313408 | This leak is behind the newAC duct leading into the closet. It actually left a puddle of water in a box on top of the cabinet. Someone came to look at ballast but didn't check on roof/ceiling that the teacher is aware of. | Roof | Whittier Elementary School | Room 40 | Roofs/Rain | 12/20/2019 | |
| 177 | 312917 | Project Kidz Connect has a storage bin located next to the bike rack. The storage bin has several leaks. Please repair. They have had to throw out materials that had water damage. | General Maintenance | Whittier Elementary School | next to bike rack | Roofs/Rain | 12/6/2019 | |
| 178 | 316128 | Roof leaks in rooms 11, 13, 42, 43, 44. New AC systems were installed over the summer. Please repair. | Roof | Whittier Elementary School | Rooms 11, 13, 42, 43, 44 | Roofs/Rain | 3/10/2020 | |
| 179 | 312194 | The ceiling is leaking heavily above carpet area. Please fix. | Roof | Whittier Preschool | Room 2 at the preschool | Roofs/Rain | 11/20/2019 | |

| | | | | | | | | |
|-----|--------|---|-----------|----------------------------|----------------------------|------------|------------|--|
| 180 | 312205 | Large leak in ceiling caused tiles to break and water and debris landed on alphabet rug. Erika Cronkite, preschool facilitator, is requesting the rug be washed tonight so that students can utilize it tomorrow. | Custodial | Whittier Preschool | Preschool Room 2 | Roofs/Rain | 11/21/2019 | Requested rug was cleaned and extracted. -mw |
| 181 | 316259 | Parking lot is flooded (3.13.2020) | Plumbing | Whittier Preschool | | Roofs/Rain | 3/13/2020 | |
| 182 | 312765 | Active roof leak in room 11-per Custodian. See Custodian Edgar. Thank you - Rosa | Roof | Wilson Elementary School | room 11 | Roofs/Rain | 12/4/2019 | |
| 183 | 316265 | Roof leak in room#14 Thank you! | Roof | Wilson Elementary School | Room#14 | Roofs/Rain | 3/13/2020 | |
| 184 | 316620 | water leaks rooms# 10-8-35-36-37-24-25-26--27-32-31-30-34 -MPR, library. | Roof | Wilson Elementary School | classrooms | Roofs/Rain | 4/9/2020 | |
| 185 | 316584 | water leak in side MPR wet ceiling tiles. Thank you! | Roof | Wilson Elementary School | MPR | Roofs/Rain | 4/7/2020 | |
| 186 | 316588 | Water leak in library. ceiling tiles wet. Thank you! | Roof | Wilson Elementary School | library | Roofs/Rain | 4/7/2020 | |
| 187 | 314460 | Roof Leak in Library (Room 1). See Custodian Erica. Thank you - Rosa [Confirmed with Librarian that this was caused by recent rains. BB] | Roof | Wilson Elementary School | Library-Room 1 | Roofs/Rain | 1/27/2020 | |
| 188 | 314203 | 2 buckets are catching leaks in room 10- carpet beginning to smell | Roof | Woodland Elementary School | room 10 | Roofs/Rain | 1/17/2020 | |
| 189 | 312456 | Ceiling is leaking in room 1 and room 10; Room 1 is dripping near the A/C; Room 10 has wet ceiling tiles, not an active leak as of this time. | Roof | Woodland Elementary School | Room 1 and room 10 | Roofs/Rain | 11/27/2019 | |
| 190 | 313352 | We found a roof leak above our IT cabinet in Woodland, Classroom 8. It looks like the ceiling tile has fallen town. Discovered on 12/11/19 by Mike Ricci x7515 | Roof | Woodland Elementary School | 8 | Roofs/Rain | 12/19/2019 | |
| 191 | 313239 | ceiling tiles are stained- stain recently grew after the rain | Roof | Woodland Elementary School | 18 | Roofs/Rain | 12/16/2019 | |
| 192 | 313478 | Ceiling in rooms , Pk3,7,10 and library are leaking from the rain. | Roof | Woodland Elementary School | Rooms, pk3, 7,10, library. | Roofs/Rain | 12/27/2019 | |
| 193 | 316571 | 3 leaks in room 11- | Roof | Woodland Elementary School | 11 | Roofs/Rain | 4/6/2020 | |
| 194 | 312710 | Water leak in the ceiling for room 9. Many tiles have fallen, please see Armando our custodian. | Roof | Woodland Elementary School | Room 9 | Roofs/Rain | 12/3/2019 | |
| 195 | 312711 | major leak in room 9- very close to IT server See photo | Roof | Woodland Elementary School | 9 | Roofs/Rain | 12/3/2019 | |
| 196 | 316272 | The classroom is leaking from the ceiling and the back window is also leaking from where the pice of metal that hold the blinds in placed I put a bucket on the window you will see where is coming from. | Roof | Woodland Elementary School | Room PK 1 | Roofs/Rain | 3/13/2020 | |