

ENVIRONMENTAL ASSISTANCE GROUP 179 NIBLICK ROAD # 401 PASO ROBLES CA. 93446 PHONE/FAX 805 2864921 E-MAIL comply@haztrainer.com

February 13, 2020

Mr. Bob Lombard, Newport Mesa Unified School District 2990 Mesa Verde Drive, Costa Mesa 92626

SUMMARY REPORT OF SAMPLING ROOFING MATERIALS FOR ASBESTOS

INTRODUCTION

On January 16, 2020 Environmental Assistance Group represented by Ed Kennedy, Certified Asbestos Consultant (CAC) collected samples of roofing materials from select buildings at Paulerino Elementary School, 1060 Paularino Avenue, Costa Mesa, California 92626, in the Newport Mesa Unified School District. The sampling was conducted because the district is planning to replace the roofing materials.

METHOD

The sampling method included collecting representative samples by coring through all layers to the substrate or cutting off small pieces. All samples were of non-friable miscellaneous materials. The samples were placed in leak tight containers and transported to a NVLAP and DHS certified laboratory, Forensic Analytical in Rancho Dominguez California, for analysis by Polarized Light Microscopy (PLM). After analysis, the results were provided for inclusion in this report.

RESULTS

The analyses showed that the majority of roof component homogenous areas of roofing materials sampled were none detected (ND) for asbestos. However, mastic/tar around roof pipe penetration are considered to all be 5% chrysotile based on positive sample results, and the boiler building roof tar is also considered to be 5% chrysotile based on positive sample results.

RECOMMENDATION

Edmi Ekunady

Because of the representative samples collected, utilize trained asbestos workers to remove the of all of the surrounding mastic/tar from all pipe penetrations to a distance of two feet. Utilize trained asbestos workers to remove all roofing materials from the entire Boiler Building roof. Removal of the remainder of the roofing materials throughout the site will not require trained asbestos workers.

Eldwin "Ed" Kennedy, CAC 93-1249, CLP 4092

Attachments: Asbestos Homogeneous Area/Sampling Form, Forensic Analytical Bulk Asbestos Analysis Report and Chain of Custody

HOMOGENOUS AREA/SAMPLING FORM ASBESTOS

Page 1 of 2 Environmental Assistance Group

179 Niblick Rd. #401 Paso Robles, CA 93446

CLIENT: <u>NMUSD</u> Office: 805-286-4921

DATE: 1-16-20 SITE: Paularino Elementary PROJECT # NMPR120

SAMPLED: <u>1-16-20</u> CERT/CAC #: <u>93-1249</u>

INSPECTOR: Eldwin "Ed" Kennedy Signature: Eddui E kunady

НА	SAMPLE	HOMOGENOUS	CONDI-	LOCATION/	BLDG/	RM/#	SAMPLE LOCATION	AMT
	#	MATERIAL	TION	SURFACE	SUITE			
1	NMPR120-1	Roof felt layers/mastic	NA	Roofs	Admin	Roof	SE area, 5' from S. edge, 4' from E. edge	ND
1	NMPR120-2	Roof felt layers/mastic	NA	Roofs	Admin	Roof	SW area, 5' from N. edge, 1' from W. edge	ND
2	NMPR120-3	Roof felt layers/penetration mastic	NA	Roof at copper pipe penetration	Admin	Roof	At penetration 8' from W. edge, 12' from N. edge	ND
1	NMPR120-4	Roof felt layers	NA	Roof field	1-3	Roof	2' from W. edge, 2' from S. edge	ND
2	NMPR120-5	Roof felt layers/penetration mastic	NA	Roof field near 1" galv. pipe penetration	1-3	Roof	1' from N. edge, 2' from E. edge	ND
1	NMPR120-6	Roof felt layers	NA	Roof field	16-17	Roof	2' from W. edge, 2' from S. edge	ND
1	NMPR120-7	Roof felt layers	NA	Roof field	16-17	Roof over 16	2' from S. edge, 20' from W. edge	ND
1	NMPR120-8	Roof felt layers	NA	Roof field	Library 5	Roof over 5	2. From N. edge, 2' from E. edge	ND
2	NMPR120-9	Roof felt layers/ penetration mastic	NA	Roof field & penetration	Library 5	Roof over Library	6' from E. edge, 20' from S. edge	5% in tar
1	NMPR120-10	Roof felt layers	NA	Roof field	14-15	Over 14	12' from E. edge, 10' from N. edge	ND
1	NMPR120-11	Roof felt layers	NA	Roof field	14-15	Over 15	Roof Field	ND
1	NMPR120-12	Roof felt layers	NA	Roof field	28-30	Over 28	1' from E. edge, 15' from N. edge	ND
1	NMPR120-13	Layers of roofing felt/tar	NA	Roof field	28-30	Over 30	5' from E. edge, 12' from S. edge	ND
1	NMPR120-14	Layers of roofing felt/tar	NA	Roof field	20-21	Over 21	30' from N. edge, 5' from E. edge	ND
1	NMPR120-15	Layers of roofing felt/tar	NA	Roof field	20-21	Over 20	Roof field	ND
1	NMPR120-16	Layers of roofing felt/tar	NA	Roof field	Boiler Bldg.	Over boiler	2" from N. edge, 10' from E. edge	5% in tar
2	NMPR120-17	Layers of gray felt/ penetration mastic	NA	Roof at corner of exhaust fan	MPR	Over	8' from W. edge, 10' from S. edge, SE corner	ND
1	NMPR120-18	Layers of gray felt/ penetration mastic	NA	At 2" pipe penetration	MPR	Over	8' from N. edge, 8' from W. edge	ND
1	NMPR120-19	Layers of felt – gray grit	NA	Roof field	MPR	Over	5' from E. edge, 15' from N. edge	ND

HOMOGENOUS AREA/SAMPLING FORM ASBESTOS

Page 2 of 2 Environmental Assistance Group

179 Niblick Rd. #401 Paso Robles, CA 93446

CLIENT: <u>NMUSD</u> Office: 805-286-4921

DATE: 1-16-20 SITE: Paularino Elementary PROJECT # NMPR120

SAMPLED: <u>1-16-20</u> CERT/CAC #: <u>93-1249</u>

INSPECTOR: Eldwin "Ed" Kennedy Signature: Eddui E kunady

НА	SAMPLE	HOMOGENOUS	CONDI-	LOCATION/	BLDG/	RM/#	SAMPLE LOCATION	AMT
	#	MATERIAL	TION	SURFACE	SUITE			
3	NMPR120-20	Gray penetration		Roof at NE	MPR	Over	SE corner curb	ND
		mastic		exhaust fan				
1	NMPR120-21	Felt layers		Roof field	Kinder-		2' from E. edge,	ND
					garten		2' from N. edge	
2	NMPR120-22	Felt layers/		Roof – old 2"	Kinder-	Over	4' from E. edge,	ND
		penetration mastic		pipe boot	garten		30' from N. edge	
2	NMPR120-23	Felt layers/		Roof field	Kinder-	Over	7' from W. edge,	ND
		penetration mastic			garten		2' from S. edge	



Bulk Asbestos Analysis

(EPA Method 40CFR, Part 763, Appendix E to Subpart E and EPA 600/R-93-116, Visual Area Estimation)

NVLAP Lab Code: 101459-1

Environmental Assistance Group Ed Kennedy PO Box 2537 Tehachapi, CA 93561 Job ID/Site: NMPR120; Paularino Eler	nentary School		Client ID: L1206 Report Number: B298630 Date Received: 01/20/20 Date Analyzed: 01/27/20 Date Printed: 01/27/20 First Reported: 01/27/20 SGSFL Job ID: L1206 Total Sampler Submitted: 23
Date(s) Collected: 01/17/2020			Total Samples Submitted: 23 Total Samples Analyzed: 23
Sample ID	Asbestos Lab Number Type	Percent in Asbestos Layer Type	Percent in Asbestos Percent in Layer Type Layer
NMPR120 1 Layer: Stones Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Total Composite Values of Fibrous Composite Values Composi	51316542 mponents: Asbestos (ND)	ND ND ND	
Cellulose (Trace) Fibrous Glass (3	•		
NMPR120 2 Layer: Stones Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts	51316543	ND ND ND	
Total Composite Values of Fibrous Co Cellulose (Trace) Fibrous Glass (3:	• • • •		
NMPR120 3 Layer: Stones Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Layer: Grey Roof Shingle	51316544	ND ND ND ND	
Total Composite Values of Fibrous Co Cellulose (Trace) Fibrous Glass (4	•		
NMPR120 4 Layer: Green Roof Shingle Layer: 2 Black Tars Layer: 2 Black Felts Layer: Grey Roof Shingle Layer: Black Felt Layer: Tan Fibrous Backing	51316545	ND ND ND ND ND ND	
Total Composite Values of Fibrous Co Cellulose (Trace) Fibrous Glass (4	• ' '		
NMPR120 5 Layer: 3 Black Tars Layer: 3 Black Felts Layer: Grey Roof Shingle Layer: Black Felts	51316546	ND ND ND ND	
Total Composite Values of Fibrous Co Cellulose (Trace) Fibrous Glass (4	-		

Client Name: Environmental Assistance Group

Chent Name: Environmental Assistance	отопр				Date Printed	01/2///	
Sample ID	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
NMPR120 6 Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts	51316547		ND ND ND				
Layer: Tan Fibrous Backing			ND				
Total Composite Values of Fibrous Con Cellulose (Trace) Fibrous Glass (35	_	sbestos (ND) etic (10 %)					
NMPR120 7 Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Layer: Tan Fibrous Backing	51316548		ND ND ND ND				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (25	-	usbestos (ND) etic (20 %)					
NMPR120 8 Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Layer: Tan Fibrous Backing	51316549		ND ND ND ND				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (25	-	sbestos (ND) etic (20 %)					
NMPR120 9 Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Layer: Metal Layer: Black Semi-Fibrous Tar	51316550	Chrysotile	ND ND ND ND 5 %				
Layer: Tan Fibrous Backing Total Composite Values of Fibrous Com	-	sbestos (Trace	ND e)				
Cellulose (Trace) Fibrous Glass (25 NMPR120 10 Layer: Grey Roof Shingle Layer: 2 Black Tars Layer: 2 Black Felts Layer: Tan Fibrous Backing	51316551	etic (20 %)	ND ND ND				
Total Composite Values of Fibrous Con Cellulose (Trace) Fibrous Glass (45	-	sbestos (ND)					
NMPR120 11 Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts Layer: Tan Fibrous Backing	51316552		ND ND ND ND				
,							

Client Name: Environmental Assistance Group

Sample ID	Lab Numbe	Asbestos r Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
NMPR120 12 Layer: Grey Roof Shingle Layer: 2 Black Tars Layer: 2 Black Felts	51316553		ND ND ND				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (45	-	Asbestos (ND)					
NMPR120 13 Layer: Black Semi-Fibrous Tar Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts	51316554		ND ND ND ND				
Total Composite Values of Fibrous Com Cellulose (2 %) Fibrous Glass (40 %	-	Asbestos (ND)					
NMPR120 14 Layer: Grey Roof Shingle Layer: 3 Black Tars Layer: 3 Black Felts	51316555		ND ND ND				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (40	_	Asbestos (ND) hetic (2 %)					
NMPR120 15 Layer: Grey Roof Shingle Layer: Grey Roof Shingle Layer: 3 Black Tars Layer: 3 Black Felts	51316556		ND ND ND ND				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (45	_	Asbestos (ND) hetic (Trace)					
NMPR120 16 Layer: Grey Roof Shingle Layer: 2 Black Tars Layer: 2 Black Felts Layer: Black Semi-Fibrous Tar	51316557	Chrysotile	ND ND ND 5 %				
Total Composite Values of Fibrous Com Cellulose (Trace) Fibrous Glass (45	-	Asbestos (Trace)				
NMPR120 17 Layer: Silver Paint Layer: Black Semi-Fibrous Tar Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars Layer: Multi-Layer Black Felts	51316558		ND ND ND ND				
Total Composite Values of Fibrous Com Cellulose (2 %) Fibrous Glass (40 %	-	Asbestos (ND)					

Client Name: Environmental Assistance Group

CHERT Name. Environmental Assista	nce oroup				Date 11 mieu	. 01/2///	
Sample ID	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
NMPR120 18	51316559		_				
Layer: Paint			ND				
Layer: Black Semi-Fibrous Tar			ND				
Layer: Grey Roof Shingle			ND				
Layer: Multi-Layer Black Tars			ND				
Layer: Metal			ND				
Layer: Multi-Layer Black Felts			ND				
Total Composite Values of Fibrous Cellulose (2 %) Fibrous Glass	_	Asbestos (ND)					
NMPR120 19	51316560						
Layer: Grey Roof Shingle			ND				
Layer: 2 Black Tars			ND				
Layer: 2 Black Felts			ND				
Layer: Tan Fibrous Backing			ND				
Total Composite Values of Fibrous Cellulose (Trace) Fibrous Glas	-	Asbestos (ND)					
NMPR120 20	51316561						
Layer: Black Semi-Fibrous Tar			ND				
Layer: Stones			ND				
-	Components	Asbestos (ND)					
Total Composite Values of Fibrous Cellulose (7 %)	Components.	Aspesios (ND)					
NMPR120 21	51316562						
Layer: Grey Roof Shingle			ND				
Layer: 2 Black Tars			ND				
Layer: 2 Black Felts			ND				
Layer: Tan Fibrous Backing			ND				
Total Composite Values of Fibrous Cellulose (Trace) Fibrous Glas	_	Asbestos (ND)					
NMPR120 22	51316563						
Layer: Grey Roof Shingle			ND				
Layer: Grey Roof Shingle			ND				
Layer: Multi-Layer Black Tars			ND				
Layer: Multi-Layer Black Felts			ND				
Total Composite Values of Fibrous	Components:	Asbestos (ND)					
Cellulose (10 %) Fibrous Glas	-	(12)					
NMPR120 23	51316564						
Layer: Grey Roof Shingle	31310304		ND				
Layer: Grey Roof Shingle Layer: Multi-Layer Black Tars							
Layer: Multi-Layer Black Felts			ND ND				
			ND				
Total Composite Values of Fibrous	_	Asbestos (ND)					
Cellulose (2 %) Fibrous Glass	(40 %)						

Client Name: Environmental Assistance Group Percent in Asbestos Asbestos Percent in Asbestos Percent in Sample ID Lab Number Layer Type Layer Type Layer Type



Tiffani Ludd, Laboratory Supervisor, Rancho Dominguez Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by SGS Forensic Laboratories (SGSFL) at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by SGSFL to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by SGSFL. The client is solely responsible for the use and interpretation of test results and reports requested from SGSFL. SGSFL is not able to assess the degree of hazard resulting from materials analyzed. SGS Forensic Laboratories reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.



Forensic Analytical Laboratories, Inc.

Analysis Request Form (COC)

Client Name & Address: Client No.:					PO/Job#: Date:					
Enviro	onmental Ass	istance Group	, L'	1206	NMPR 120 1-18-20 Turn Around Time: Same Day / 1Day / 3Day / 4Day 5Day					
PO Box 2537				Turn Around Time: Same Day / 1Day / 2Day / 3Day / 4Day / 5Day □ PCM: □ NIOSH 7400A / □ NIOSH 7400B □ Rotometer						
Tehachapi CA 93581										
Conta	act:				PLM: Stand					
1	ennedy				☐ TEM Air: ☐ AI	Quantitativ	ve / 🗖 Qualita	tive / 🗖	Chatfield	
Phon	e: Office: 66 Cell: 66	51-822-8762 1-304-8981	Fax:	22-8762	☐ TEM Water: ☐ ☐ TEM Microvac					(str/mass)
E-ma		1-304-0361	001-02	22-8702	☐ IAQ Particle Id				☐ PLM Opaq	
	oly@HazTrair nician: Eldwi				☐ Particle Identif		<u>_</u>	1	3 Special Pro	ject
	# 93-1429	CLP # 4092	·		Matrix:	15. INEUIO				
Site L	ocation:	ريو ايد د		Flowentam Sc					·	·
Comr	ments:	<u>u</u>	of 2	Elementary Sc	160 (Report Via	:		
	1	/	04>				☐ Fax	X ☐ E	-Mail □\	/erbal
на	Sam	ple tD	Date /	Sample Location / De	psczintion		FOR AIR SAM	MPLES ON	LY	Sample Area /
"^	Jain	pie io	Time	Sample Eccation / Di	escription	Туре	Time On/Off	Avg. LPM	Total Time	Air Volume
						A _P				
ļ	MAPI	R 1201	1-17-20			C A				
		2	}			PC		-		
						A				
ļ		3				С				
		/4				PC				
		4		" "		Α	 			
						PC				
						A _P				
		6	 			A				
		7				P				
		_				A P				
<u> </u>		8	 -			AC			•	
		9				РС				
		10		£		A P				
Samp	oled By: Eld	win Kenned			Date:		Time:			A
	ed Via: 🗖 Fe	<u> </u>	<i></i>	☐ US Mail ☐ Courier	XII Drop Off	Other:				
Reling	uished By: Eld	win Kenne		Relinquished By:			Relinquished B	by:		
Date /	Time:	18-20	9.45	Date / Time:			Date / Time:			
Receiv	ved By: D	un Ge	rde D	Received By:	= =		Received By:			
Date /	Time: 1/2	0(90	9:54a	Date / Time:			Date / Time:			
Date / Time: 1.18-20 9.45 A Date / Time: Received By: Down Good Dy Received By: Date / Time: 1/20/20 9.5 4 an Date / Time: Condition Acceptable? 9 Yes 9 No Condition Acceptable? 9				Yes 🗆 No		Condition Acce	eptable? [J Yes □ I	No	



Forensic Analytical Laboratories, Inc.

Analysis Request Form (COC)

Client Name & Address: Client No.:	PO/Job#: NMPR	120	Date:	1-1	7-20	5	
Environmental Assistance Group L1206		Turn Around Time: Same Day / 1Day / 2Day / 3Day / 4Day 5Day					
PO Box 2537 Tehachapi CA 93581	☐ PCM: ☐ NIOSH	□ PCM: □ NIOSH 7400A / □ NIOSH 7400B □ Rotometer					
	PLM: (Standa	ard / 🗇 F	Point Count 400	- 1000 /	☐ CARB 435		
Contact: Ed Kennedy	☐ TEM Air: ☐ AH	-	•				
Phone: Office: 661-822-8762 Fax:	☐ TEM Water: ☐	Potable	/ 🗖 Non-Potal	ole / 🗖 W	Veight %		
Cell: 661-304-8981 661-822-8762	☐ TEM Microvac: ☐ IAQ Particle Ide] / ∐ 05756(☐ PLM Opaqu		
comply@HazTrainer.com	Particle Identifi				Special Pro		
Technician: Eidwin Kennedy CAC # 93-1429 CLP # 4092	☐ Metals Analysis	: Method	d:				
Site Location:	Matrix:		·-··				
Paulorino Elementan Sch	Analytes:		Donort Via	_			
Paularina Elementary Sch Comments: 2 of 3			Report Via		-Mail □ V	erbal	
Date /			FOR AIR SAM	APLES ON	LY	Sample Area /	
HA Sample ID Time Sample Location	on / Description	Туре	Time On/Off	Avg. LPM	Total Time	Air	
12.25		A_	Ollyon	LFIVI	Time	Volume	
NM PR 120 11 1-17-20		P C					
		A P					
1 12 1		A					
/3		P					
		A P					
4		A C					
15		P					
		PC					
	<u> </u>	A					
		PC					
		A P					
1 18		A					
19		PC					
20		A P C					
Sampled By: Eldwin Kennedy	Date: ,	+	Time:			<u>l</u>	
Shipped Via:	er XD Drop Off D				·		
Relinquished By: Eldwin Kenned Relinquished By:		 -T	Relinquished B	y:			
Date / Time: / - 18 - 20 \$9.45 Date / Time:			Date / Time:				
Received By: Dienn Gan D/8 Received By:			Received By:		·· ·····		
Pate / Time: 1-18-20 \$9.45 Date / Time: Received By: Drewn Garry Dr. Received By: Date / Time: 1/8/20 9/54 an Date / Time:			Date / Time:				
Condition Acceptable? Yes No Condition Acceptable	le? □ Yes □ No		Condition Acce	eptable? (JYes □ ſ	No	



Forensic Analytical Laboratories, Inc.

Analysis Request Form (COC)

				· · · · · · · · · · · · · · · · · · ·						
Client Name & Address: Client No.:				PO/Job#: Date: 1-17-20						
H	onmental Assistance Group ox 2537	p L120)6	Turn Around Time: Same Day / 1Day / 2Day / 3Day / 4Day / 5Day						
Tehachapi CA 93581				□ PCM: □ NIOSH 7400A / □ NIOSH 7400B □ Rotometer						
			PLM: Stand	ard / 🗆 F	oint Count 400	0 - 1000 /	☐ CARB 435	; 		
Conta				☐ TEM Air: ☐ AF		-			,	
	ennedy e: Office: 661-822-8762	Fax:	<u> </u>	☐ TEM Bulk: ☐ C						
Priori	Cell: 661-304-8981	661-822-	·8762	TEM Microvac:					(str/mass)	
E-ma				☐ IAQ Particle Ide				☐ PLM Opaqe	-	
	nician: Eldwin Kennedy			☐ Metals Analysis				7 Special Fro	уест	
CAC #	# 93-1429 CLP # 4092		· ·	Matrix:			•			
Site L	ocation:	· 15104	. a. Louis Colore	Analytes:						
Comr	ments:	MOKIEM	newlary Schoo	I		Report Via	:			
	3 OK	<u> </u>				☐ Fax	k X□E-	Mail 🗆 V	/erbal	
		Date /				FOR AIR SAI	MPLES ON	LY	Sample Area /	
НА	Sample ID	Time	Sample Location / De	scription	Туре	Time	Avg.	Total	Air	
		-	- 10 M. II.		A	On/Off	LPM	Time	Volume	
	NHPR 12021	1-12-20			PC			ı		
					Α		+			
	22	<u> </u>			PC		<u> </u>	<u> </u>		
		,			A P		Ţ			
	- + 4	} 			A	ļ			 	
					PC		-	ı		
					Α		 		 	
					PC				,	
					A P					
 					C					
					P		-			
		+			A C		 		 	
					PC		1			
					A					
ļ		 -			<u> </u>	-	<u> </u>			
					PC					
Samp	oled By: Eldwin Kenne	.7	[Date: 1-17-	20	Time:	<u></u>			
Shipp	ed Via: □ Fed Ex □ DH	IL UPS C		(Drop Off (
Reling	uished By: Eldwin Kenne	6	Relinquished By:	NAME .		Relinquished B	By:			
Date /	Time: /- /9- 20	9.4	Date / Time:			Date / Time:				
Receiv	red By: Dizun Ger	va 2/0	Received By:			Received By:				
Date /	Time: /- 18-20 ved By: Dian Ger Time: 18/20 @	9:54	Date / Time:			Date / Time:				
Condition Acceptable? Yes				Yes □ No Condition Acceptable? □ Yes □ No					No	